

## Ventilation: response to COVID-19 pandemic

Memorial recognizes ventilation is another control to minimize the spread of COVID-19. An important consideration is that good ventilation is just one of the many layers of protection against virus spread, which includes high vaccination rates, proper wearing of masks, use of rapid testing, staying home if you have symptoms, physical distancing, proper cough etiquette and more.

The Office of the Chief Risk Officer (OCRO) established a COVID-19 Heating, Ventilation and Air Conditioning (HVAC) working group to review and consider implementation of technical recommendations to enhance building ventilation systems and reduce the risk of airborne aerosol exposure. The working group includes representatives from: Facilities Management on St. John's, Marine Institute and Grenfell campuses and OCRO.

There are numerous sources of information regarding ventilation and transmission; during the COVID-19 pandemic Memorial is following guidance from multiple sources including the American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE) pandemic taskforce recommendations, Public Health Agency of Canada and the Centre for Disease Control.

Literature sources consistently recommend an approach of:

- Increasing air filtration, while still maintaining comfortable indoor air temperature and humidity
- Regular maintenance of building HVAC systems; and
- Opening windows or doors where possible or feasible

## Types of mechanical ventilation

Memorial has many types of buildings from the new state of the art Core Science Facility to original buildings built in the 1950s. Some buildings are mechanically ventilated; others rely on natural ventilation (e.g. windows) and some have a combination of both. Of those buildings that have mechanical ventilation systems, some buildings have 100% fresh air supply, others have re-circulated air with filters at various design amounts; a building with mechanical ventilation may or may not have air conditioning; some buildings have humidification systems and some building systems have carbon dioxide detectors, which can increase fresh air into a space.

Memorial has conducted ventilation assessments of all identified classrooms on the St. John's, Grenfell and Marine Institute campuses to determine the type of ventilation. Classrooms have various ventilation types either mechanical or natural (operable windows), that meet or exceed recommended guidelines. Maintenance is conducted on mechanical ventilation systems to ensure the filters are changed and the system is operating as intended. Facilities Management has also replaced the MERV 8 filters where possible with higher rated MERV 13 filters. This improves the efficiency of capturing any small particles in the air.

Building ventilation systems are designed for occupant health and comfort; and they take into account factors such as the space use, number of people that will occupy the space, and

heating/cooling requirements. **Air exchange rates or air changes per hour (ACH) are generally not used as a principle design target except in special areas such as laboratories and animal care facilities, which have regulated ACH rates.**

In addition to various measures to improve ventilation to mitigate COVID-19 risk, experts on the [ASHRAE Epidemic Task Force for Core Recommendations for Reducing Airborne Infectious Aerosol Exposure](#) recommends HVAC systems when necessary to flush spaces between occupied periods, operate systems for a time required to achieve three air changes of equivalent clean air supply.

## Mechanical ventilation systems at Memorial

Memorial has implemented a comprehensive process to review all HVAC systems on campus to ensure they meet COVID-19 public health and safety guidelines. The following table summarizes the type of changes being made to the mechanical ventilation systems:

|   | PRE-COVID-19 BUILDING HVAC CONDITION        | COVID-19 BUILDING HVAC CONDITION (a)                     |
|---|---|--|
| <b>HVAC Maintenance Schedule</b>  | Scheduled Maintenance                       | HVAC System Inspection, Enhancement, Ongoing Maintenance |
| <b>HVAC Filtration</b>  | MERV-8<br>Filters 3 to >10 micron particles | MERV-13 (a)<br>Filters 0.3 to >10 micron particles       |
| <b>HVAC Runtime/Occupied Schedule</b>   | 12-16 Hour Runtime                          | Increased by 1-3 hours                                   |
| <p><b>a. ASHRAE recommends ensuring HVAC systems can handle filter and ventilation upgrades without negative impacts to pressure differentials and/or air flow rates.</b></p> |   |  |

## Risk based approach

To ensure a safe indoor environment, the working group has prioritized our campus teaching spaces. Memorial has a risk matrix to guide decision making for the use of classrooms and teaching spaces on campus. **List of assessed teaching spaces is available (Appendix A)**

|            | Mechanical Ventilation                                     | Natural Ventilation (Windows)   | No Ventilation                       |
|------------|--|---|--------------------------------------|
| Classrooms | Use at pre-pandemic capacity and/or less than 100 in space | Up-graded with additional measures to use at pre-pandemic capacity and/or have specific occupant instructions | Not used until further re-assessment |
| Wet Labs   | Use at pre-pandemic capacity                               | Not used until further re-assessment  | Not used until further re-assessment |

Risk Level:

Low

Moderate

High

## Types of spaces and recommendations for occupants

| Types of Spaces  | Recommendations for Occupants  |
|--|--|
| Teaching spaces:<br><b>Classrooms and Teaching labs</b>  | <ul style="list-style-type: none"> <li>▪ A summary of teaching spaces equipped with mechanical ventilation, teaching spaces that have been upgraded, and teaching spaces that are not being used for regular teaching activities for Winter 2022 is maintained.</li> <li>▪ As of January 31, 2022, all teaching spaces with mechanical ventilation are available for use at pre-pandemic capacity. Limited or no mechanical ventilated spaces are being assessed.</li> </ul>   |
| Mechanically ventilated spaces:<br><b>Spaces designed with mechanical ventilation that is driven by fans or other mechanical equipment within a building</b>           | <ul style="list-style-type: none"> <li>▪ Where mechanical system design allows, main air handling units are equipped with MERV 13 air filtration. Air filters are on a preventative maintenance schedule for replacement</li> <li>▪ Where possible, HVAC systems with CO2 monitoring are set to bring in outside air if CO2 levels rise.</li> <li>▪ Where possible, operating HVAC systems for an additional time for pre or post occupancy flush, and reviewing the time of day main air handling units are scheduled to turn off and on and mirror them with the times the building is primarily occupied. Systems continue to run at low levels after hours where possible.</li> <li>▪ Wet labs are designed with systems to provide adequate ACH.</li> </ul> |
| Naturally ventilated spaces:<br><b>Spaces without mechanical ventilation systems equipped with operable windows.</b>   | <ul style="list-style-type: none"> <li>▪ Occupants should open windows and doors to bring in as much fresh air without compromising occupant comfort (temperature) or security.</li> <li>▪ Do not leave windows open when you vacate the room or overnight as it may result in too much cold air, security risks and rodents entering the building.</li> <li>▪ Refer to <a href="#">Memorial's Natural Ventilation Guideline</a></li> </ul>  |
| Non-mechanically ventilated spaces without windows: <b>Spaces without mechanical ventilation systems and are not equipped with windows or where windows don't open</b> | <ul style="list-style-type: none"> <li>▪ Limit use of space to one user.</li> <li>▪ Open doors in area as long as possible without compromising security.</li> <li>▪ If needed, contact EHS at <a href="mailto:health.safety@mun.ca">health.safety@mun.ca</a> to arrange a ventilation assessment of your naturally ventilated space with no windows or windows that do not open. Requests should only be made by supervisors.</li> </ul>  |

# Appendix A

## Assessed teaching spaces

## St. John's Campus

|         |         |          |                     |
|---------|---------|----------|---------------------|
| A 1002  | BN 3007 | ED 1014  | ED 4011             |
| A 1043  | BN 3010 | ED 1020  | ED 4014             |
| A 1045  | BN 3037 | ED 1023  | ED 4015             |
| A 1046  | C 2003  | ED 2002  | ED 4034             |
| A 1049  | C 2004  | ED 2003  | ED 4051             |
| A 2065  | C 2022  | ED 2004  | ED 5006 and<br>5007 |
| A 2071  | C 2024  | ED 2018A | ED 5012             |
| A 3017  | C 2026  | ED 2018B | ED 5021             |
| A 3018  | C 2033  | ED 3005  | EN 1000             |
| A 3020  | C 2045  | ED 3008  | EN 1001             |
| A 3033  | C 3033  | ED 3011  | EN 1002             |
| A 4004  | C 3053  | ED 3023  | EN 1003             |
| A 4049D | C 3055  | ED 3030  | EN 1004             |
| A 5014  | C 4002  | ED 3034A | EN 1019             |
| A 5032  | C 4011  | ED 3034B | EN 1020             |
| BN 1008 | C 4036  | ED 3048  | EN 1040             |
| BN 1009 | CS 1009 | ED 4008  | EN 1051             |
| BN 1010 | CS 1019 | ED 4009  | EN 1052             |
| BN 2028 | ED 1005 | ED 4010  | EN 1054             |

|                     |           |           |           |
|---------------------|-----------|-----------|-----------|
| EN 2006             | ER 3008B  | H 3454    | MED 1M102 |
| EN 2007             | ER 3009B  | HH 3013   | MED 1M109 |
| EN 2022             | ER 3010   | HH 3015   | MED 1M111 |
| EN 2040             | ER 4000   | HH 3017   | MED 1M112 |
| EN 2043             | ER 5000   | IIC 1033  | MED 1M113 |
| EN 2048             | H 1622    | IIC 1035  | MED 1M114 |
| EN 2050             | H 1758    | IIC 2001  | MED 1M115 |
| EN 2056             | H 2768    | IIC 2002  | MED 1M116 |
| EN 2078             | H 2815    | J 2008    | MED 1M117 |
| EN 3000 and<br>3029 | H 2860    | J 2014    | MED 1M118 |
| EN 4008             | H 2862    | J 3004    | MED 2767  |
| EN 4020             | H 2864    | J 3008    | MED 2815  |
| EN 4033             | H 2908    | J 3014    | MED 2819  |
| EN 4034             | H 2910    | J 3015    | MED 2820  |
| EN 4035             | H 2911    | L 1006    | MED 2821  |
| ER 3005B            | H 2956    | L 2028    | MED 2824  |
| ER 3006A            | H 3427    | MED 1849  | MED 2826  |
| ER 3007B            | H 3444    | MED 1852  | MED 2827  |
| ER 3007C            | H 3446    | MED 1M101 | MED 2828  |
| MED 2829            | MED 4M119 | PE 2001   | SN 3125A  |
| MED 2860            | MED 5209  | PE 2028   | SN 4038   |

|           |                        |         |          |
|-----------|------------------------|---------|----------|
| MED 2862  | MED 5227               | QC 1000 | SN 4040  |
| MED 2864  | MED 5M100              | QC 1004 | SN 4063  |
| MED 2865  | MED 5M101              | QC 4028 | SN 4068  |
| MED 2866  | MED<br>THEATRE A       | SN 1103 | SN 4073  |
| MED 2868  | MED<br>THEATRE D       | SN 2018 | SN 4078  |
| MED 2J549 | MED MAIN<br>AUDITORIUM | SN 2036 | SN 4083  |
| MED 2J618 | MU 1001                | SN 2041 | SN 4087  |
| MED 2J619 | MU 1026                | SN 2064 | SN 4110  |
| MED 2M114 | MU 1032                | SN 2067 | SN 4116F |
| MED 2M218 | MU 1034                | SN 2098 | UC 2001  |
| MED 2M240 | MU 1045                | SN 2101 | UC 4005  |
| MED 3M101 | MU 1050                | SN 2105 | UC 4007G |
| MED 3M203 | MU 2017                | SN 2109 | UC 4010A |
| MED 3M300 | MU 2021                | SN 3038 | UC 4010B |
| MED 3M626 | MU 2025                | SN 3042 | UC 4011  |
| MED 4M117 | MU 2033                | SN 3058 | UC 4015  |
| MED 4M118 | 1 PE 2000              | SN 3060 | UC 4016  |



MED 3M300

MED 3M626

MED 4M117

MED 4M118

MU 2021

MU 2025

MU 2033

PE 2000

SN 3038

SN 3042

SN 3058

SN 3060

UC 4010B

UC 4011

UC 4015

UC 4016

QC-3005

BN 3002

BN 3008

BN 3009

BN 2015

QC-2011

QC 2013

QC 3004

QC-2003

ED 2031

SN 1019

## Grenfell Campus

AS 228

AS 229

AS 304

AS 305

AS 324

AS 325

AS 3005

AS 3009

AS 3032

AS 326

AS 328

AS 329

AS 350

AS 375

AS 378

AS 379

AS 383

AS 2011

AS 2016

AS 2026

AS 3003

FC 3019

FC 3024

LC 202

LC 301

FA 223

FA 224

FC 2014

## Marine Institute

E1310

E1300

E1302

E1306C

E1307

E1320

E1321

E2317

E3300

E3301

E3303

E2302

E1311

E1319

W1000D

W1003

W1006

W1016

W1018

W1019

W1021

W1023

W2032

W2034

W2036

W2040

W2048

W2054

W3004

W2026

W3005

W3010/12

W3029/31

W3033/35

W1039

W1119

E3327

E3206

E1303

E2300

E2304A

E2327

E3315

E2305

E2311

E2313

C3226

C3228

E3323

C3208

E2325

W1004

W1002

W1008

W2046

C3208

W3018A

W1004B