

Memorial University Water Quality Testing Results
The maximum allowable concentration for lead is 10 micrograms per litre, as published by Health Canada
2016 Sampling Results

Building	Location	Date Sampled	Initial Sample		Date Sampled	Re-Sample 1		Date Sampled	Re-Sample 2	Comments
			First draw (µg/L)	5 Minute Sample (µg/L)		First Draw (µg/L)	5 Minute Sample (µg/L)			
1 Clark Place	CJ-2000A	25-Nov-16	1	0.5						
6 Clark Place	CM-2000	25-Nov-16	1.8	0.8						
202 Elizabeth Ave	CE-1004	25-Nov-16	0.6	0.4						
208 Elizabeth Ave	BP-2001	25-Nov-16	0.8	0.4						
307 Mt. Scio (Staff House)	BS-2000	07-Dec-16	8.3	2.1						
330 Botanical Garden Caretaker Res	BC-2002	07-Dec-16	0.7	0.6						
Aquarena*	AQ-2019	23-Nov-16	25.3	6.2	02-Dec-16	13.4	5.3			This location is now filtered to remove lead.
Aquarena	AQ-3017	23-Nov-16	0.4	0.3						
Arts & Administration	A-1001B	26-Oct-16	5	1.6						
Arts & Administration	A-3047	26-Oct-16	0.3	<0.2						
Arts & Administration	A-5021	26-Oct-16	0.4	<0.2						
Barnes House	BA-217	02-Dec-16	3.2	1						
Blackall House	BL-105	09-Dec-16	0.8	0.3						
Bruneau Ctr for Research & Innov	IIC-3002	18-Nov-16	0.5	0.6						
Bruneau Ctr for Research & Innov	IIC-3036	19-Nov-16	1.2	0.5						
Burke House	BU-110	02-Dec-16	0.4	<0.2						
Business Administration*	BN-1015M	10-Nov-16	175.1	50.7	07-Dec-16	154	57.3	13-Jan-17	65.1	This location remains out of service under investigation.
Business Administration	BN-4012	22-Nov-16	6.4	2.7						
Business Administration	BN-4033A	10-Nov-16	0.9	0.4						
C-CORE - Cold Ocean Research Eng	K-2012	10-Nov-16	0.8	0.2						
C-CORE: Dr J Clark Geotech Eng Bldg	CF-2002	10-Nov-16	1.9	0.6						
C-CORE: Dr J Clark Geotech Eng Bldg	CF-4021	10-Nov-16	<0.2	<0.2						
Chemistry-Physics	C-1011	16-Dec-16	4.1	1.6						
Chemistry-Physics	C-1008	12-Jan-17	4.5	3.6						
Chemistry-Physics	C-2012B	29-Nov-16	3	0.9						
Chemistry-Physics	C-3023	16-Dec-16	10.3	3						
Chemistry-Physics	C-4019	29-Nov-16	0.7	0.3						
Cluett Hall	EX-1012A	09-Dec-16	1.6	1.1						
Corte Real*	CA-2002	09-Dec-16	73.1	23.3	10-Jan-17	1163	70.5	20-Jan-17	4.7	There was a water main break in this building. This location is now filtered to remove lead.
Coughlan College*	CL-1007	10-Nov-16	8.5	34.1						This location is not occupied and remains out of service.
Coughlan College	CL-1010	10-Nov-16	2.5	0.9						
Coughlan College	CL-2004	27-Oct-16	4.3	5.5						

Memorial University Water Quality Testing Results
The maximum allowable concentration for lead is 10 micrograms per litre, as published by Health Canada
2016 Sampling Results

Building	Location	Date Sampled	Initial Sample		Date Sampled	Re-Sample 1		Date Sampled	Re-Sample 2	Comments
			First draw (µg/L)	5 Minute Sample (µg/L)		First Draw (µg/L)	5 Minute Sample (µg/L)			
Coughlan College	CL-2023	27-Oct-16	2.2	< 0.2						
Curtis House	CU-100B	02-Dec-16	0.8	0.3						
Doyle House	DO-109	02-Dec-16	0.2	<0.2						
Earth Sciences	ER-4068	22-Nov-16	1.1	0.5						
Earth Sciences	ER-6029	22-Nov-16	2.5	1.2						
Education*	ED-2030B	26-Oct-16	17.1	4.2	15-Nov-16	16.3	1.1	25-Nov-16	0.4	This location is now filtered to remove lead.
Education*	ED-5010	26-Oct-16	9.8	3	15-Nov-16	10.8	3.2	25-Nov-16	2.5	Tap was cleaned before going back in service
Engineering & Applied Sciences	EN-2023	23-Nov-16	2.6	4.4						
Engineering & Applied Sciences	EN-4004	23-Nov-16	2.8	0.8						
Facilities Management	FM-1027	30-Nov-16	2.7	0.9						
Facilities Management	FM-2038B	30-Nov-16	0.4	0.6						
Faculty of Medicine Extension	M-2M100	29-Nov-16	0.4	<.2						
Faculty of Medicine Extension	M-4M120	29-Nov-16	0.5	0.2						
Feild Hall	GH-1003	27-Oct-16	<0.2	<0.2						
Feild Hall	GH-4010	27-Oct-16	<0.2	<0.2						
Field House	FH-2006B	26-Oct-16	1	0.5						
Hatcher House	HA-111	01-Dec-16	0.4	<0.2						
Hatcher House	HA-201	01-Dec-16	0.3	<0.2						
Health Sciences Centre	H-1643	29-Nov-16	6.2	2.3						
Main Dining Hall	DH-1002	01-Dec-16	1.4	0.5						
Main Dining Hall	DH-2006A	01-Dec-16	59.1	14	14-Dec-16	41.7	16.5	10-Jan-17	13.4	This location is now filtered to remove lead.
Mathematics	HH-2047	24-Nov-16	2.1	0.8						
Music*	MU-1046	18-Nov-16	45.5	14						This unit has been permanently removed from service
Physical Education & Athletics	PE-2003B	23-Oct-16	1.7	1.5						
Queen's College*	QC-3014	27-Oct-16	16.2	6.4						Currently on bottled water.
Queen's College	QC-4001	28-Oct-16	8.3	3						
Queen's College	QC-4001B	28-Oct-16	1.1	1.3						
Rothermere House	RO-100	02-Dec-16	0.4	<0.2						
Science	SN-1094	18-Nov-16	1.5	0.6						
Science	SN-3101	24-Nov-16	1	0.6						
Shiwak Hall	WX-1012	09-Dec-16	2.1	1.4						
Spencer Hall	SP-3010	27-Oct-16	7.7	4.4						

Memorial University Water Quality Testing Results
The maximum allowable concentration for lead is 10 micrograms per litre, as published by Health Canada
2016 Sampling Results

Building	Location	Date Sampled	Initial Sample		Date Sampled	Re-Sample 1		Date Sampled	Re-Sample 2	Comments
			First draw (µg/L)	5 Minute Sample (µg/L)		First Draw (µg/L)	5 Minute Sample (µg/L)			
Squires House	SQ-107	02-Dec-16	0.4	<0.2						
University Centre	UC-2002D	22-Nov-16	1	0.5						
Utilities Annex	UA-2002	18-Nov-16	2.7	0.9						
Vivarium	V-1	07-Dec-16	7.5	2.2						
4 Clark Place	CK-1001	30-Nov-16	1.8	0.5						
Baltimore	BM-303	20-Dec-16	0.7	0.2						
Baltimore	BM-304	20-Dec-16	0.4	0.8						
Battery Residence	B-1112	05-Apr-17	<0.2	<0.2						
Battery Residence	B-5100	05-Apr-17	<0.2	<0.2						
Bowater	BO-114	29-Mar-17	0.4	<0.2						
Cabot	CT-104	09-Dec-16	1	0.7						
Cabot	CT-204	09-Dec-16	2.9	1.3						
Cartier	CR-111	20-Dec-16	8.4	2						
Cartier	CR-111B	20-Dec-16	1.1	0.7						
Cartier	CR-109	20-Dec-16	0.7	0.5						
Gilbert	GB-102	20-Dec-16	1.3	0.3						
Gilbert	GB-103	20-Dec-16	0.9	0.4						
Guy	GY-102	20-Dec-16	0.5	0.3						
Guy	GY-105	20-Dec-16	0.8	0.3						
Library	L1021	26-Oct-16	0.9	0.7						
St. John's College	J-3010	22-Nov-16	2.8	1.1						
Child Care Centre	CH-2005	18-Nov-16	2.5	0.9						

* Location required further investigation due to elevated results