

Memorial University Water Quality Testing Results

The maximum allowable concentration for lead is 10 micrograms per litre, as published by Health Canada

2017 Sampling Results

Building	Location	Date Sampled	Initial Sample		Date Sampled	Re-Sample 1		Comments
			First draw (µg/L)	5 Minute Sample (µg/L)		First Draw (µg/L)	5 Minute Sample (µg/L)	
Group 1								
Queen's College	QC-4000	12-Dec-17	9.2	2.6				
Queen's College	QC-3016	17-Jan-18	6.9	1.8				
Feild Hall	GH-1000	12-Dec-17	0.7	<0.5				
Spencer Hall	SP-1000	12-Dec-17	1.5	<0.5				
Coughlan College*	CL-1007	12-Dec-17	10.5	2.3	17-Jan-18	12.5	3.5	This location is now filtered to remove lead
C-CORE: Dr J Clark Geotech Eng Bldg	CF-4021	12-Dec-17	<0.5	<0.5				
Business Administration	BN-4033A	13-Dec-17	4.5	1.6				
Business Administration	BN-4011	13-Dec-17	4.7	1.6				
Engineering & Applied Sciences	EN-2116B	13-Dec-17	0.6	<0.5				
Earth Sciences (CERR)	ER-6028	14-Dec-17	2.6	1.2				
Earth Sciences (CERR)	ER-4065	14-Dec-17	1.8	<0.5				
Group 2								
University Centre	UC-3005B	13-Dec-17	2.7	0.8				
Utilities Annex	UA-2002	13-Dec-17	9.7	2.3				
Faculty of Medicine Extension*	M-2M215	13-Dec-17	<0.5	<0.5	02-Feb-18	<0.5	<0.5	
Faculty of Medicine Extension*	M-2M212	13-Dec-17	14.4	2.4	17-Jan-18	13.6	2.4	This location is now filtered to remove lead
Faculty of Medicine Extension Blank	M-2M212	13-Dec-17	1.3	<0.5				
Science	SN-3125A	13-Dec-17	1	<0.5				
Science	SN-2013	12-Dec-17	2.7	1.3				
Arts & Administration	A-5006	12-Dec-17	0.7	<0.5				
Arts & Administration	A-2001F	12-Dec-17	1.2	<0.5				
Bruneau Ctr for Research & Innov	IIC-1001L	12-Dec-17	7.2	0.6				
Group 3								
Chemistry-Physics	C-4019	13-Dec-17	1.4	0.6				
Chemistry-Physics	C-2012B	13-Dec-17	3.9	1.4				
Physical Education & Athletics*	PE-3000	13-Dec-17	15.7	8.2				This location is now filtered to remove lead
Field House	FH-1016	13-Dec-17	0.9	<0.5				
Education	ED-5006	13-Dec-17	2.2	1.1				
Education	ED-3000B	13-Dec-17	3.1	1				

*Location required further investigation due to elevated results

Memorial University Water Quality Testing Results

The maximum allowable concentration for lead is 10 micrograms per litre, as published by Health Canada

2017 Sampling Results

Building	Location	Date Sampled	Initial Sample		Date Sampled	Re-Sample 1		Comments
			First draw (µg/L)	5 Minute Sample (µg/L)		First Draw (µg/L)	5 Minute Sample (µg/L)	
Group 4								
Cluett Hall	EX-3015	20-Dec-17	2	0.7				
Cluett Hall	EX-1012	20-Dec-17	1.9	1.2				
Hatcher House	HA-324	20-Dec-17	<0.5	<0.5				
Hatcher House	HA-106	20-Dec-17	<0.5	<0.5				
Hatcher House Blank	HA-106	20-Dec-17	<0.5	<0.5				
Main Dining Hall*	DH-2006A	20-Dec-17	67.3	13.3				This location is now filtered to remove lead
Main Dining Hall	DH-1002	12-Dec-17	2.7	0.6				
Shiwak Hall	WX-3015	19-Dec-17	1.4	0.9				
Facilities Management*	FM-2004	19-Dec-17	28.5	7.1	17-Jan-18	27	7.7	One unit was permanently removed from service; the other unit is now filtered to remove lead
Group 5								
Barnes House	BA-106	19-Dec-17	1.3	0.5				
Blackall House	BL-100	19-Dec-17	2.5	0.5				
Bowater House	BO-114	19-Dec-17	<0.5	<0.5				
Bowater House	BO-122	19-Dec-17	0.8	<0.5				
Curtis House	CU-100	19-Dec-17	0.7	<0.5				
Doyle House	DO-102	20-Dec-17	<0.5	<0.5				
Rothermere House	RO-216	19-Dec-17	1.1	<0.5				
Squires House	SQ-109	20-Dec-17	0.6	<0.5				
Group 6								
Baltimore Court	BM-104	20-Dec-17	1.8	0.5				
Baltimore Court	BM-105	20-Dec-17	0.6	<0.5				
Cabot Court	CT-302	20-Dec-17	<0.5	<0.5				
Cabot Court Blank	CT-302	20-Dec-17	3.5	<0.5				
Cabot Court	CT-103	20-Dec-17	<0.5	<0.5				
Cartier Court	CR-302	20-Dec-17	<0.5	<0.5				
Cartier Court	CR-102	19-Dec-17	5	1.2				
Corte Real	CA-1000G	20-Dec-17	7	6.4				
Gilbert Court	GB-302	19-Dec-17	<0.5	<0.5				
Gilbert Court	GB-110	19-Dec-17	<0.5	<0.5				

*Location required further investigation due to elevated results

Memorial University Water Quality Testing Results

The maximum allowable concentration for lead is 10 micrograms per litre, as published by Health Canada

2017 Sampling Results

Building	Location	Date Sampled	Initial Sample		Date Sampled	Re-Sample 1		Comments
			First draw (µg/L)	5 Minute Sample (µg/L)		First Draw (µg/L)	5 Minute Sample (µg/L)	
Guy Court	GY-302	19-Dec-17	3.2	1.1				
Guy Court	GY-110	19-Dec-17	<0.5	<0.5				

*Location required further investigation due to elevated results