

Memorial University Water Quality Testing Results
The maximum allowable concentration for lead is 5 micrograms per litre, as published by Health Canada
2021 Sampling Results

Building	Location	Date Sampled	Initial Sample		Date Sampled	Re-Sample 1		Date Sampled	Re-Sample 2	Comments
			First draw (µg/L)	5 Minute Sample (µg/L)		First Draw (µg/L)	5 Minute Sample (µg/L)			
Arts and Administration	A-1001B	08-Dec-21	10.7	3.4						
Arts and Administration	A-3047	08-Dec-21	0.99	<0.3						
Facilities Management	FM-1027	08-Dec-21	3.6	0.66						
Music	MU-1046	08-Dec-21	0.56	0.39						
Science	SN-3101	08-Dec-21	0.79	3.7						
Chemistry-Physics	C-2012B	08-Dec-21	2.3	0.76						
Physical Education	PE-2003B	08-Dec-21	9.3	2.7						
Earth Sciences	ER-6029	08-Dec-21	2.9	0.46						
Engineering	EN-4004	10-Dec-21	214	82.9						Resolved
Engineering	EN-4004	20-Dec-21	207	77.6						Resolved
Business	BN-4011	10-Dec-21	2.9	0.35						
208 Elizabeth Avenue	BP-2001	14-Dec-21	1.1	0.62						
4 Clarke Place	CK-1001	14-Dec-21	3.5	0.73						
202 Elizabeth Avenue	CE-1004	14-Dec-21	0.78	<0.3						
Cabot Court	CT-305	14-Dec-21	<0.3	<0.3						
Hatcher House	HA-111	14-Dec-21	0.32	<0.3						
Cluett Hall	EX-2019	14-Dec-21	0.58	0.34						
Corte Real	CA-2002	14-Dec-21	0.54	0.45						