

Memorial University Water Quality Testing Results
The maximum allowable concentration for lead is 10 micrograms per litre, as published by Health Canada
2018 Sampling Results

Building	Location	Date Sampled	Initial Sample		Date Sampled	Re-Sample 1		Date Sampled	Re-Sample 2	Comments
			First draw (µg/L)	5 Minute Sample (µg/L)		First Draw (µg/L)	5 Minute Sample (µg/L)			
Alumni Affairs and Development	LL-2005	2019-Jan-09	3.4	1.2						
Arts and Administration	A-4049F	2018-Dec-21	1.6	<0.5						
Arts and Administration	A-3037	2018-Dec-21	1.1	<0.5						
Baltimore	BM-101	2018-Dec-18	0.7	<0.5						
Blackhall	BL-3C01	2018-Dec-19	3	1						
Business Administration	BN-4012	2018-Dec-21	7.6	1.7						
Cartier	CR-102	2018-Dec-18	0.9	<0.5						
Chemistry-Physics	C-3023	2018-Dec-21	3.7	1.4						
Coughlan College	CL-2004	2018-Dec-21	5.8	1.7						
Curtis	CU-109	2018-Dec-19	0.7	<0.5						
Education	ED-4037	2018-Dec-21	8.2	3.1						
Education	ED-5013	2018-Dec-21	18.2	4						
Engineering	EN-2023	2018-Dec-21	33.7	9.5						Aerotor was full. Staff lounge.
Facilities Management	FM-2034	2018-Dec-21	12.1	3.4						Aerotor cleaned
Faculty of Medicine	M-2M212	2019-Jan-09	8.9	0.9						
Faculty of Medicine	M-2M212	2018-Jan-17	13.6	2.4						Aerorator cleaned
Faculty of Medicine	M-2M212	2018-Jan-17	1.7	<0.5						
Faculty of Medicine	M-2M-212	2018-Oct-24	3.5	0.6						
Faculty of Medicine	M-2M215	2018-Feb-02	<0.5	<0.5						
Faculty of Medicine	M-2M239	2019-Jan-09	3.6	1						
Faculty of Medicine Blank	M-2M-239	2019-Jan-09	<0.5	<0.5						
Faculty of Medicine	M-4M400	2019-Jan-09	9.8	2.1						
Faculty of Medicine	M-5M115	2019-Jan-09	<0.5	<0.5						
Field Hall	GH-3010	2018-Dec-21	<0.5	<0.5						
Field Hall	GH-4009	2018-Dec-21	<0.5	<0.5						
Gilbert	GB-111	2018-Dec-18	0.7	0.5						
Hatcher	HA-206	2018-Dec-19	1.8	0.5						
Hatcher	HA-411	2018-Dec-18	<0.5	<0.5						
Hatcher	HA-205	2018-Dec-19	1.1	<0.5						
Hatcher	HA-123	2018-Dec-18	0.5	<0.5						
Queen's College	QC-2013	2018-Dec-19	86.4	34.5						No aerator on faucet. Sink in classroom. On bottled water. New taps installed.
Queen's College	QC-3007	2018-Oct-24	1.5	0.6						On bottled water
Queen's College	QC-1015	2018-Oct-24	0.9	<0.5						On bottled water
Queen's College	QC-2013	2018-Oct-24	75	22.3						On bottled water
Queen's College	QC-3016	2018-Jan-17	6.9	1.8						
Science	SN-1107B	2018-Dec-18	58.7	13.9						Laboratory - not a drinking water location

