

Memorial University Water Quality Testing Results
The maximum allowable concentration for lead is 5 micrograms per litre, as published by Health Canada
2019/2020 Sampling Results

Building	Location	Date Sampled	Initial Sample		Date Sampled	Re-Sample 1		Comments
			First draw (µg/L)	5 Minute Sample (µg/L)		First Draw (µg/L)	5 Minute Sample (µg/L)	
Arts and Administration	A-5014	2019-Dec-17	1.3	0.8			73.1	
Barnes	BA-101C	2019-Dec-18	0.4	<0.3				
Blackhall	BL-100B	2019-Dec-18	3	<0.3				
Bruneau	IIC-1033A	08-Jan-20	0.6	<0.3				
Bruneau	IIC-1033A B1	08-Jan-20	<0.3	<0.3				
Business	BN-4012	09-Jan-20	1.2	3.9				
Cabot	CT-101	2019-Dec-18	<0.3	<0.3				
Cartier	CR-206	2019-Dec-18	0.3	<0.3				
Chemistry-Physics	C-1011	2019-Dec-17	2.6	0.7				
Corte Real	CA-2002	14-Jan-20	0.4	0.3				
Coughlan College	CL-2023	14-Jan-20	0.6	<0.3				
Dining Hall	DH-1002	2019-Dec-20	1.9	0.4				
Earth Sciences	ER-6056	08-Jan-20	125.7	31.9				Taken out of service during investigation. Filtered
Education	ED-5013	08-Jan-20	14.2	2.9				Aerorator cleaned
Education	ED-4037	08-Jan-20	5.8	1.6				Aerorator cleaned
Education	ED-1009	13-Mar-20	0.4	<0.3				
Engineering	EN-2023	09-Jan-20	3.7	1				
Facilities Management	FM-2018	16-Jan-20	2.8	0.9				
Facilities Management	FM-2034	2019-Dec-20	9.5	2.6				Taken out of service during investigation. Filter installed
Facilities Management - Blank	FM-2018	16-Jan-20	<0.3	<0.3				
Facilities Management*	FM-2018	2019-Dec-18	0.6	N/A				Chilled and filtered drinking water location - Filter in place during sampling
Guy	GY-201	2019-Dec-17	0.4	<0.3				
Guy	GY-103	2019-Dec-17	0.3	<0.3				
Medical Education Centre	M400	11-Jan-20	9.7	1.7	31-Jan-20	20.5	1.4	Fixtures changed. Filtered
Music	MU-1046	2019-Dec-20	36.2	12.8				Taken out of service during investigation. Filter installed
Queen's College	QC-2013	15-Jan-20	67.1	14.5				On bottled water
Queen's College	QC-4001	15-Jan-20	11.9	3.3				On bottled water
Queen's College	QC-3014	15-Jan-20	32.6	12.6				On bottled water
Queen's College	QC-3019	15-Jan-20	13.4	7.6				On bottled water
Queen's College	QC-4000	14-Jan-20	8.7	2.4				On bottled water
Queen's College	QC-3016	14-Jan-20	5.9	1.4				On bottled water
Science	SN-2013	2019-Dec-20	1	0.4				
Spencer Hall	SP-3010	11-Jan-20	8.7	2.2	31-Jan-20	12.1	2.5	Aerorator cleaned
University Centre	UC-2002D	09-Jan-20	1.5	0.3				
Utilities Annex	UA-2002	11-Jan-20	13.1	2.4	31-Jan-20	14.9	2.5	Aerorator cleaned