

Memorial University Water Quality Testing Results
The maximum allowable concentration for lead is 5 micrograms per litre, as published by Health Canada
2023 Sampling Results

Building	Location	Date Sampled	Initial Sample		Date Sampled	Re-Sample 1		Date Sampled	Re-Sample 2	Comments
			First draw (µg/L)	5 Minute Sample (µg/L)		First Draw (µg/L)	5 Minute Sample (µg/L)			
Arts and Administration	A-1021	Aug 4 23	3.4		Aug 18 23	6.5		Sept 19 23	2.5	
Arts and Administration	A-2601	Sept 19 23	2.1							
Henrietta Harvey	HH-2047	Aug 4 23	2.8		Sept 19 23	1.3				
Music	MU-1046	Aug 4 23	2.7		Sept 19 23	0.6				
Facilities Management	FM-2018	Aug 4 23	0.8		Sept 19 23	2				
South Campus Boiler Plant	BR-1001A	Aug 4 23	1.3		Sept 19 23	0.8				
Business	BN-DWC-01	Aug 18 23	2.7							
Earth Sciences	ER-4C01	Aug 18 23	<0.5							
Core Science Facility	CSF-DWC-04	Aug 18 23	<0.5							
University Centre	UC-DWC-01	Aug 18 23	<0.5							
Education	ED-DWC-10	Aug 18 23	0.6							
Physical Education	PE-DWC-05	Aug 18 23	1.1							
Arts and Administration	A-DWC-07	Aug 18 23	<0.5							